









JAK WYBRAĆ ODPOWIEDNIE URZĄDZENIE GRZEWcze?

	Powierzchnia		Kubatura					
	Elektryczne	Gazowe	Elektryczne			Gazowe		Olejowe
								
	IR-2	PARASOL 12 kW INOX	RED-HOT VARIO 3 kW	RED-HOT 3,3 kW	RED-HOT 15 kW	K-15	K-30	K-37
Budynki dobrze izolowane	6 m ²	Niezalecane	40 m ² 100 m ^{3*}		80 m ² 200 m ^{3*}	120 m ² 300 m ^{3*}	360 m ² 900 m ^{3*}	360 m ² 900 m ^{3*}
Budynki izolowane	6 m ²	Niezalecane	18 m ² 45 m ^{3*}		40 m ² 100 m ^{3*}	48 m ² 120 m ^{3*}	240 m ² 600 m ^{3*}	240 m ² 600 m ^{3*}
Budynki nieizolowane	6 m ²	Niezalecane	Niezalecane			32 m ² 80 m ^{3*}	140 m ² 350 m ^{3*}	140 m ² 350 m ^{3*}
Na zewnątrz	Niezalecane	20 m ²	Niezalecane			Niezalecane		

* Przy wysokości sufitu 2,50 m.