

Romus
13-15 rue du Taillefer
91160 Champlan
France

Your notice of	Your reference	our reference	date
		PW/2108	2013-10-01

Certification Report Nr. 13/2108

1. Description of the flooring:

Product group: entrance matting

2. Executed tests:

European Fire classification in accordance with EN 13501-1 (2002)		
Class	EN ISO 11925-2 (15 s surface flame attack) or EN 14041 (2004)	EN ISO 9239-1 (test duration = 30 min)
E _{fl}	F _s ≤ 150 mm within 20 s	No requirement

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

E_{fl}

loose-laid on a combustible or non combustible substrate***

** End use substrates of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.2)*

*** End use substrates of wood and of classes A1 and A2-s1,d0 (ISO 13238:2010 § 5.2.3)*

This certification report runs to 2 pages and may be reproduced, as long as it is presented in its entire form, without written permission of Centexbel.


The results of the analysis cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is recognized as notified body 0493 for the European Construction Products directive and the European directive for personal protective equipment

CENTEXBEL GENT
Technologiepark 7
BE-9052 Zwijnaarde (Gent)
Tel. +32 9 220 41 51
Fax +32 9 220 49 55
e-mail gent@centexbel.be

CENTEXBEL BRUSSELS
Montoyerstraat 24-B2
BE-1000 Brussels
Tel. +32 2 287 08 30
Fax +32 2 230 68 15
e-mail brussel@centexbel.be

CENTEXBEL VERVIERS
Avenue du Parc 38
BE-4650 Herve (Chaineux)
Tel. +32 87 32 24 30
Fax +32 87 34 05 18
e-mail chaineux@centexbel.be



Addressee
ROMUS

our ref.
PW/2108


date
2013-10-01

page number
2

Related commercial names to this product group are:

QUICK MAT
QUICK ALU
QUICK TRIO
QUICK STAR
SCRAPEX

The obtained classification is based on the next test reports:
UGent: 12-746 of 30-10-2012



Petra Wittevrongel
product certifier